
The FR-E700 SC Series



The FR-E700 SC series with SLV control sets new standards for compact vector-controlled drive systems. The inverters of the FR-E700 SC series are exceptionally versatile and powerful, packed with advanced features like the Soft PWM system for reducing motor noise, adjustable torque limiting, automatic motor configuration and an integrated brake transistor (except FR-E720S-008SC and 015SC). Additionally the FR-E700 SC has the security function "Safety stop and Safe Torque Off" respectively (STO) conforming to EN 61800-5-2.

Output range:

FR-E720S SC: 0.1–2.2 kW, 200–240 V AC, single-phase

FR-E740 SC: 0.4–15 kW, 380–480 V AC, three-phase

Available accessories:

Optional control units, versatile options and useful accessories are available for this frequency inverter.

Please refer to page 38 for details.

Technical Details FR-E700 SC

Product line			FR-E7	FR-E720S- <u></u> SC-EC/-E6						FR-E740SC-EC/-E6									
Product IIn	e		008	015	030	050	080	110	016	026	040	060	095	120	170	230	300		
	Rated motor capacity [kW] ^①		0.1	0.2	0.4	0.75	1.5	2.2	0.4	0.75	1.5	2.2	3.7	5.5	7.5	11	15		
	Rated output capacity [kVA] ②		0.3	0.6	1.2	2	3.2	4.4	1.2	2	3	4.6	7.2	9.1	13	17.5	23		
Output	Rated current [®]		A 0.8 (0.8)	1.5 (1.4)	3 (2.5)	5 (4.1)	8 (7)	11 (10)	1.6 (1.4)	2.6 (2.2)	4 (3.8)	6 (5.4)	9.5 (8.7)	12	17	23	30		
	Overload capacity ⁽⁴⁾			150 % of rated motor capacity for 60 s; 200 % for 3 s															
	Voltage ©			3-phase AC, 0 V to power supply voltage															
	Power supply voltage			1-phase, 200–240 V AC, -15 %/+10 % 3-phase, 380–480 V AC, -15 %/+10 %															
Innut	Voltage range			170–264 V AC at 50/60 Hz 325–528 V AC at 50/60 Hz															
Input	Power supply frequency			50/60 Hz ± 5 %															
	Rated input capacity ® kVA		VA 0.5	0.9	1.5	2.5	4	5.2	1.5	2.5	4.5	5.5	9.5	12	17	20	28		
Control specifi- cations	Control method		V/f co	V/f control, optimum excitation control, general-purpose magnetic flux vector control or advanced magnetic flux vector control															
	Modulation control		Sine e	Sine evaluated PWM, Soft PW															
	Carrier frequency		0.7-1	0.7–14.5 kHz (user adjustable)															
	Frequency range Hz		Hz 0.2-4	0.2–400															
	Frequency resolution	Analog	0.12 H	0.06 Hz/0–50 Hz (terminal 2, 4: 0–10 V/10 Bit) 0.12 Hz/0–50 Hz (terminal 2, 4: 0–5 V/9 Bit) 0.06 Hz/0–50 Hz (terminal 4: 4–20 mA/10 Bit)															
	resolution	Digital	0.01 H	lz															
	Frequency precisio		$\pm 0.5\%$ of max. output frequency (temperature range 25 °C \pm 10 °C) during analog input; $\pm 0.01\%$ of max. output frequency during digital input																
	Voltage/frequency characteristics			Base frequency adjustable from 0 to 400 Hz; Constant torque/variable torque pattern can be selected															
	Possible starting to	≥ 200	\geq 200 %/0.5 Hz when advanced magnetic flux vector control is set (3.7 K or less)																
	Torque boost	Manu	Manual torque boost																
	Acceleration/decel	0.01-	0.01–360 s, 0.1–3600 s (may be set individually for acceleration and deceleration)																
	Acceleration/deceleration characteristics		cs Linear	Linear or S-pattern acceleration/deceleration mode selectable															
	Braking torque	regenerative ®	150 %)	100 %		50 %	20 %	100 %		50 %	20 %							
	braking torque	DC braking	0pera	ting frequ	ency: 0–1	20 Hz, ope	rating tim	e: 0–10 s,	voltage: 0)-30 % (e	xternally a	adjustable)						
	Current stall preve	Respo	nse thresh	old 0-200) %, user a	djustable													
	Motor protection	Electro	onic motor	protectio	n relay (ra	ted curren	t user adju	ıstable)	Electronic motor protection relay (rated current user adjustable)										

Remarks:


Explanation for ① to ② see next page.

Product line				FR-E720S-□SC-EC/-E6						FR-E740SC-EC/-E6								
roauct iine	!			800	015	030	050	080	110	016	026	040	060	095	120	170	230	300
	Frequency setting values	Analog input	t			DC, 0–10 DC, 0–10		–20 mA										
		Digital input		From operation panel or parameter unit, Frequency setting increment can be set. 4 digit BCD or 16bit binary data (when the option FR-A7AX-Ekit-SC-E is used)														
Control signals for operation	Input signals			Any of 7 signals can be selected using parameters 178 to 184 (input terminal function selection): multi-speed selection, remote setting, stop-on contact selection, second function selection, terminal 4 input selection, JOG operation selection, PID control valid terminal, brake opening completion signal, external thermal input, PU-external operation switchover, V/F switchover, output stop, start self-holding selection, forward rotation, reverse rotation command, inverter reset, PU-NET operation switchover, external-NET opera- tion switchover, command source switchover, inverter operation enable signal, PU operation external interlock														
	Operation functions			Maximum/minimum frequency setting, frequency jump operation, external thermal relay input selection, automatic restart after instantaneous power failure operation, forward/reverse rotation prevention, remote setting, brake sequence, second function, multi-speed operation, stop-on contact control, droop control, regeneration avoidance, slip compensation, operation mode selection, offline auto tuning function, PID control, computer link operation (RS485)														
	Safety function "Safe Torque Off"			The signal for the safe shutdown of the output can be applied to the terminals S1 and S2. (in accordance with the safety standards EN ISO 13849-1 category 3, PLd EN62061, IEC61508 SIL2)														
	Output signals	Operating sta	atus	Can be selected using parameters 190 to 192 (output terminal function selection): inverter operation, up-to-frequency, overload alarm, output frequency detection, regenerative brake prealarm, electronic thermal relay function prealarm, inverter operation ready, output current detection, zero current detection, PID lower limit, PID upper limit, PID forward/reverse rotation output, brake opening request, fan alarm®, heatsink overheat pre-alarm, deceleration at an instantaneous power failure, PID control activate safety monitor output, safety monitor output 2, during retry, life alarm, current average value monitor, remote output, alarm output, fault output 3, maintenance timer alarm.										e rotatio ivated,				
		Analog signa	ıl	0-10 V I	DC													
	Display on the operation panel or parameter unit	Operating sta	atus	Output frequency, motor current (steady or peak value), output voltage, frequency setting, cumulative energization time, actual operation time, motor torque, converter output voltage (steady or peak value), regenerative brake duty, electronic thermal relay function load factor, output power, cumulative power, motor load factor, PID set point, PID measured value, PID deviation, inverter I/O terminal monitor, I/O terminal option monitor, motor thermal load factor, inverter thermal load factor														
Display option	FR-PU07	Alarm displa	у	Fault definition is displayed when the fault occurs and the past 8 fault definitions (output voltage/current/frequency/cumulative energization time right before the fault occurs) are stored.														
	Additional displays	Operating sta	atus	Not used														
		Interactive operating gu	ide ®	Interactive guide for operation and troubleshooting via help function														
Protection	Functions			during coverhead option utance ov overcurr	onstant sp t, input ph nit error [©] erheat, co ent stall p	peed, over nase failur p, parame mmunica revention	voltage di e, output ter error, i tion error, , overvolta	uring dece side earth internal bo analog in age stall p	leration, ir (ground) f oard fault, put error,	nverter pro ault overc PU discon USB comn PU stop, p	otection th current at s nection, re nunication parameter	nermal op start, outp etry count error, bra write erro	eration, m out phase t excess [®] , ake sequer or, regene	otor prote failure, ex CPU fault nce error [©] rative bral	ection the ternal the , brake tra , safety ci ke prealar	ring accele rmal opera rmal relay insistor ala ircuit fault, m, electro orque off	ntion, head operation rm, inrush , fan alarn	tsink 1 [®] , h resis- n [®] ,
	Protection rating			IP20														
Others	Cooling			Self-coo	ling		Fan cool	ling		Self-coo	ling	Fan cool	ing				Self-coo	oling
	Power loss [W]			14	20	32	50	85	115	40	55	90	100	180	240	300	400	500
	Weight [kg]			0.6	0.6	0.9	1.4	1.5	2.0	1.4	1.4	1.9	1.9	1.9	3.2	3.2	6.0	6.0
	Dimensions (WxHxD) [mm]			68x128x86.5 68x128 108x128 108x128 x148.5 x167 x167 x167 x167 x167 x167 x167 x167									0x196					
Order in-																		
Order in-	Single painted PCB		Art. no.	234795	234796	234797	234798	234799	234800	234801	234802	234803	234804	234805	234806	234807	234808	23480

Remarks:

- ① The applied motor capacity indicated is the maximum capacity applicable for use of the Mitsubishi Electric 4-pole standard motor.
- $\ \ \, \ \,$ The rated output current in the parentheses applies for an ambient temperature less than 40 °C.
- The % value of the overload capacity indicated is the ratio of the overload current to the inverter's rated output current. For repeated duty, allow time for the inverter and motor to return to or below the temperatures under 100 % load.
- ⑤ The maximum output voltage does not exceed the power supply voltage. The maximum output voltage can be changed within the setting range. However, the pulse voltage value of the inverter output side voltage remains unchanged at about √2 that of the power supply.
- The braking torque indicated is a short-duration average torque (which varies with motor loss) when the motor alone is decelerated from 60 Hz in the shortest time and is not a continuous regenerative torque. When the motor is decelerated from the frequency higher than the base frequency, the average deceleration torque will reduce. Since the inverter does not contain a brake resistor, use the optional brake resistor FR-ABR-(H) when regenerative energy is large. A brake unit FR-BU2 or BU2 may also be used. (Option brake resistor cannot be used for FR-E720S-008SC and 015SC.)
- The power supply capacity varies with the value of the power supply side inverter impedance (including those of the input reactor and cables).
- ® FR-E720S-050SC or above, FR-E740-040SC or above
- This operation guide is only available with option parameter unit (FR-PU07).
- This protective function does not function in the initial status.
 For overseas types refer to page 78.

Block Diagram FR-E700 SC



Assignment of Signal Terminals

Function	Terminal	Designation	Description
	STF	Forward rotation start	The motor rotates forward, if a signal is applied to terminal STF. When the STF and STR signals are turned on simultaneously, the stop command is given.
Control	STR	Reverse rotation start	The motor rotates reverse, if a signal is applied to terminal STR. When the STF and STR signals are turned on simultaneously, the stop command is given.
connection	RH, RM, RL	Multi-speed selection	Preset of 15 different output frequencies (fixed frequencies).
	RES	RESET input	Used to reset alarm output provided when protective function is activated. Turn on the RES signal for more than 0.1 s, then turn it off. Initial setting is for reset always. By setting Pr. 75, reset can be set to enabled only at an inverter alarm occurrence. Recover about 1 s after reset is cancelled.
Common	SD Contact input common (sink) 24 V DC power supply common		A determined control function is activated, if the corresponding terminal is connected to the terminal SD (sink logic). The SD terminal is isolated from the digital circuits via optocouplers. The terminal is isolated from the reference potential of the analog circuit (terminal 5).
	PC	Contact input common (source) 24 V DC power supply	24 V DC/0.1 A output; reference potential for source logic
	10	Voltage output for potentiometer	Output voltage 5 V DC Max. output current 10 mA Recommended potentiometer: 1 k Ω , 0.5 W linear
Setting value specification	2	Input for frequency setting value signal	The voltage setting value $0-5$ (10) V is applied to this terminal. The voltage range is preset to $0-5$ V. The input resistance is $10 \text{ k}\Omega \pm 1 \text{ k}\Omega$.
specification	5	Reference point for frequency setting value signal	Terminal 5 is the reference point for all analog setting values and for the analog output signal AM. The terminal is not isolated from the reference potential of the control circuit and must not be earthed.
	4	Input for current setting value signal	The current setting value signal 4–20 mA DC (0–5(10) V) is applied to this terminal. The input resistance is $233\Omega\pm5~\Omega$
	A, B, C	Relay output (alarm output)	The alarm is output via relay contacts; programmable. The maximum contact load is 230 V AC/0.3 A or 30 V DC/0.3 A.
	RUN	Signal output for motor operation	The output is switched low, if the inverter output frequency is equal to or higher than the starting frequency. The output is switched high, if no frequency is output or the DC brake is in operation (programmable).
Signal outputs	FU	Signal output for monitoring output frequency	The output is switched low once the output frequency exceeds a value preset in parameter 42 (or 43). Otherwise the FU output is switched high (programmable).
·	SE	Reference potential for signal outputs	Reference potential for the signals RUN and FU. This terminal is isolated from the reference potential of the control circuit PC/SD.
	AM	Analog voltage output	One of 18 monitoring functions can be selected, e.g. external frequency output. The functions are determined by parameters. A DC voltmeter can be connected. The max. output voltage is 10 V.
Interface	_	PU connector (RS485)	Communications via RS485 1/O standard: RS485, Multi-Drop operation, max. 38,400 Baud
interrate	_	USB connector	The FR Configurator can be operated by connecting the inverter to the personal computer through USB. Interface: conforms to USB 1.1; Transmission speed: 12 MBaud; Connector: USB mini B connector (receptacle mini B type)
Safety connection	\$1,\$2	Safety inputs	Remove the shortening wire and connect the safety relay module when using the safety stop function.

Assignment of Main Circuit Terminals

Function	Terminal	Designation	Description						
	L1, N	Power supply 1-phase	onnect to the commercial power supply.						
	R/L1, S/L2, T/L3	Power supply 3-phase	Keep these terminals open when using the harmonic converter (FR-HC) or power regeneration common converter (FR-CV).						
	+,-	External brake unit connection	Connect the brake unit (FR-BU2), power regeneration common converter (FR-CV) or harmonic converter (FR-HC).						
Main circuit connection	+, PR	External brake resistor connection	Connect a brake transistor (FR-ABR) across terminals + and PR. (The brake resistor can not be connected to the FR-E720S-008SC and 015SC.)						
	+, P1	DC reactor connection	Remove the jumper across terminals + and P1 and connect a DC reactor.						
	U, V, W	Motor connection	Voltage output of the inverter (3-phase, 0 V up to power supply voltage, 0.2—400 Hz)						
	<u>-</u>	PE	Protective earth connection of inverter						